

# Quality Control

epiROOF®

## PLYWOOD SUBSTRATE READINESS CHECKSHEET

Project Name: \_\_\_\_\_

Subcontractor: \_\_\_\_\_

Area ready: \_\_\_\_\_

Fax Number: \_\_\_\_\_



CD structural grade H3.2CCA treated kiln dried and min 17mm thick

Sheets stagger laid (fully offset), with 3mm gaps between sheets, with sanded c-face upwards and face grain at right angles to supports or crossmembers.

Plywood installed with correct falls and no ponding.

5mm clearances from all abutments.

Sheet edges supported, fixed 150mm on edges and 200mm through girth.

Grade 316 stainless steel countersunk screw fixing, 50 gauge x 50mm or a length three times that of the plywood thickness.

Fillets installed to all internal junctions and neatly fitted.

5mm radius to all external corners.

Mitres neatly formed.

Rainwater outlets and overflow recesses formed in substrate to fit proprietary outlets.

Plywood dry (maximum 20% moisture).

Sharp edges and lips removed and cavities filled. All joints flush.

Substrate clean, firm and suitable condition for laying

Plinths formed for any exterior ventilation, fixtures or similar

WHEN THE SUBSTRATE IS READY, COMPLETE THIS FORM AND FAX TO THE WATERPROOFING SUBCONTRACTOR

### Notes

\_\_\_\_\_

\_\_\_\_\_